

GUIDE:
DEP Form 62-555.900(7) - Notice of Intent to Use the General Permit
for Construction of Water Main Extensions for PWSs

This guide is designed to assist the permittee in avoiding common form errors and does ***not*** relieve the preparer of responsibility to provide complete and accurate information. Staff may offer comments on items not addressed below. This guide does ***not*** need to be submitted with the form.

Part I - General Project Information

- Part I.A Enter Project Name (copy name of project on top of each page of the form)
- Part I.B: Enter applicable information. Include lengths, size(s), and material type(s) of all mains.
- Part 1.G & 1.H: For Public Water Supply System supplying water to the project indicate the Collier County Water Sewer District with information provided in the template.

Part II - Preliminary Design Report for Project

- Part II.A.1: Enter applicable information.
 - Anticipated future development needs to be included.
 - Always use a maximum day peaking factor of 1.35.
- Part II.A.1.a: Only describe/explain commercial, institutional and/or industrial facilities.
- Part II.A.4: Revise the design service pressure range if approved by Utility Deviation.
- Preparer must sign, seal, and date prior to PUEPMD approval.

Part III - Certifications

- Part III.A: Permittee must sign and date prior to PUEPMD approval.
- Part III.D: Preparer must initial, sign, seal, and date prior to PUEPMD approval.