



NOTES:

1. THIS DETAIL IS ONLY APPLICABLE FOR VALVES THAT HAVE BEEN SPECIFICALLY CALLED TO BE INSTALLED IN A VAULT
2. VAULT SHALL BE A FLAT TOP TYPE J, SCHEDULE D STRUCTURE WITH A TYPE 7 MANHOLE TOP, IN ACCORDANCE WITH F.D.O.T. STANDARD INDICES NO. 200 AND 201.
3. ALL VALVES SHALL BE OF THE RESILIENT SEATED TYPE IN ACCORDANCE WITH AWWA C 509.
4. LETTERING FOR THE VALVE COVER BOX SHALL READ "WATER".

SUBAQUEOUS WATER MAIN VALVE VAULT DETAIL