



**NOTES:**

1. ALL ABOVE GROUND PIPE SHALL BE PAINTED PANTONE PURPLE 522-C.
2. THIS INCLUDES ALL STORAGE AND REPUMP FACILITIES TO BE TURNED OVER AND DEDICATED TO THE COUNTY.
3. ALL ABOVE GROUND PIPES WILL BE FLANGED END. ALL NUTS & BOLTS SHALL BE STAINLESS STEEL.
4. (4) VEHICULAR GUARD POSTS TO BE INSTALLED AROUND METER. SUBMIT FOR REVIEW AND APPROVAL. CONFIGURATION TO BE ILLUSTRATED ON CONSTRUCTION DOCUMENTS.
5. ALL PLANTING SHALL BE A MINIMUM OF 3' FROM EDGE OF SLAB, AND SHALL PROVIDE A 3' ACCESS OPENING.
6. ALL PIPES UNDER 3" SHALL BE BRASS.
7. METER ASSEMBLY SHALL BE LOCATED WITHIN C.U.E.
8. REFER TO NP-ELECTRICAL DETAILS FOR ADDITIONAL REQUIREMENTS AND CONDITIONS.

**STANDARD NON-POTABLE IRRIGATION METER ASSEMBLY SERVICE CONNECTION**