



DESCRIPTION: When regular continuous footings are used, call for inspection when footings are excavated, neat, clean, dry and forms are in place, level, braced and reinforcing bar if required is in place and tied. Reinforcing bar must be suspended in place a minimum of (3) inches above the soil. If footings are on fill, you must have a compaction report by an engineer on job site at time of inspection.