

525- Final electrical work performed, storm shutters residential. Arc fault protection required for extended circuits.

