



SIDE VIEW

NOTES:

1. MJ TAPPED CAP WITH HOSE BIBB IS TO BE REMOVED AFTER INITIAL BACTERIOLOGICAL CLEARANCE AND PRIOR TO WATER MAIN ACCEPTANCE.
2. SEE TECHNICAL SPECIFICATIONS SECTION 15100 FOR GATE VALVE AND VALVE BOX REQUIREMENTS.

TEMPORARY BLOWOFF ASSEMBLY WITH
BACTERIAL SAMPLE POINT DETAIL

NTS

W-1

REVISED: APRIL 2006