

RECORDED VIDEO INSPECTION GUIDE: WATER HEATER CHANGE OUT

Permit Number: _____ Address: _____

NOTICE: These requirements are provided as general guidance for Recorded Video Inspections; the guide is not intended to be comprehensive in nature. Specific work may require additional video documentation to clearly present the scope of work. Inspectors reserve the right to visit any site to verify details. Inspectors have the authority to convert a Recorded Video inspection to an in-person inspection at their sole discretion. All work must demonstrate compliance with current codes and standards.

INTRODUCTION:

All Water Heater Change Out Video Inspections must begin with the Following:

- 1. Providing close-up of address numbers
- 2. State your name, company, date & time
- 3. Permit Card

GAS:

Video must include:

- 1. Flue clearance from combustibles
- 2. H&C water lines for clearance from flue
- 3. Flue pipe for required self-tapping screws
- 4. Double wall flue pipe through penetrations
- 5. Check for draft (if possible)
- 6. Flue terminus
- 7. Soap test

ELECTRIC:

Video must include:

- 1. Hard wired
- 2. Disconnect within 50 ft. with clear sight to breaker panel
- 3. Lock out tag out, if breakers in another room

GAS/ELECTRIC:

Video must include:

- 1. Relief drip
- 2. Drip pan
- 3. Drip pan drain
- 4. Expansion tank supported
- 5. TP valve if no expansion tank
- 6. No water leaks
- 7. Check gallons reflect description on permit
- 8. Check for level and stability
- 9. Accessible for maintenance
- 10. Shut off valve on cold water feed

I _____ (printed name of submitter), as an authorized person to upload video inspection files in accordance with Collier County Virtual Inspection procedures, have reviewed the video and have verified items above have been checked by the installer prior to uploading to BOX, as required by Collier County requirements.

Signature

Date