

RECORDED VIDEO INSPECTION GUIDE: WATER PIPE REPLACEMENT (217)

Permit Number: _____ Address: _____

NOTICE: These requirements are provided as general guidance for Recorded Video Inspections; the guide is not intended to be comprehensive in nature. Specific work may require additional video documentation to clearly present the scope of work. Inspectors reserve the right to visit any site to verify details. Inspectors have the authority to convert a Recorded Video inspection to an in-person inspection at their sole discretion. All work must demonstrate compliance with current codes and standards.

INTRODUCTION:

All Water Pipe Replacement Video Inspections must begin with the following:

- 1. Providing close-up of address numbers
- 2. State your name, company, date & time
- 3. Permit Card

WATER PIPE REPLACEMENT:

Video must include:

- 1. Pressure test
 - Leak free installation can be confirmed two ways:
 - 1. Show 80 psi gauge (show gauge at beginning and end of video)
 - 2. Run faucet to show that system is pressurized at normal operating pressure and video all joints
- 2. Nail plates
- 3. Hammer arrestor (DW, WM, Icemaker)
- 4. Hot water to DW
- 5. Pipe support every 4 feet
- 6. Vacuum breaker on hose bibb
- 7. Protective sleeve through masonry
- 8. Piping not in contact with sharp objects/edges
- 9. Grommets for steel stud penetrations
- 10. No kinks or bends beyond 90 degrees (flexible pipe)

I _____ (printed name of submitter), as an authorized person to upload video inspection files in accordance with Collier County Virtual Inspection procedures, have reviewed the video and have verified items above have been checked by the installer prior to uploading to BOX, as required by Collier County requirements.

Signature

Date