



**Local Limits Effective  
March 2019 (FDEP Approval 3/18/19)**

Parameters	Local Limit (mg/L)	
<b>Arsenic</b>	1.4 mg/L	Over the limit for any of these is <b>prohibited</b>
<b>Cadmium</b>	0.01 mg/L	
<b>Chromium</b>	4.7 mg/L	
<b>Copper</b>	1.0 mg/L	
<b>Cyanide</b>	0.1 mg/L	
<b>Lead</b>	0.2 mg/L	
<b>Mercury</b>	0.02 mg/L	
<b>Molybdenum</b>	0.2 mg/L	
<b>Nickel</b>	1.3 mg/L	
<b>Selenium</b>	0.09 mg/L	
<b>Silver</b>	0.02 mg/L	
<b>Zinc</b>	1.0 mg/L	
<b>pH</b>	>5.0 and <10.0	Out of range is <b>prohibited</b>

The statement below can be found in the Collier County Pretreatment Amended Ordinance No. 2012-13.

The Local Limits are established “pursuant to subsection 62-625.400(3), F.A.C., and as such, no person shall discharge wastewater containing pollutants in excess of the local limits for those pollutants which have been established for Collier County Publicly Owned Treatment Works (POTW) using standard procedures, calculations and methods acceptable to the State to protect against pass through or interference, protections of POTW employees and adverse affects on wastewater residuals disposal.”

